

Name: Xi'an High Voltage Apparatus Research Institute Co., Ltd.

Address: No.18, North Section of Xi'erhuan, Xi'an, Shaanxi, China

Registration No. CNAS PT0141

Accreditation Criteria: ISO/IEC 17043:2023 and relevant requirements of CNAS

Effective Date: 2025-06-24 Expiry Date: 2030-05-09

SCHEDULE 2 ACCREDITED PROFICIENCY TESTING SCOPE FOR TESTING

№	Sample	Item/Parameter		Note	Effective Date
		№	Item/Parameter		
1	Samples of copper platoon	1	Loop resistance value R_{20} (DC100A、20℃)		2025-06-24
2	power frequency voltage equipment	1	Power frequency voltage test	The testing capabilities applicable to equipment products for power transmission and distribution in voltage levels ranging from 10kV to 35kV	2025-06-24
3	High-current test simulation items	1	Peak current test of electrical equipment/Peak current (10kA-200kA)	The testing capabilities applicable to equipment products for power transmission and distribution in test current ranging from 10kA to 200kA	2025-06-24



No. CNAS PT0141

第 1 页 共 1 页

The scope of the accreditation in Chinese remains the definitive version.